

**California Public Health Goals (PHGs),
Existing California and Federal Drinking Water Standards:
First 26 Chemicals (25 Documents, 27 Values)**

| Chemical | California PHGⁱ ppbⁱⁱ | California MCLⁱⁱⁱ ppb | Federal MCL ppb | Federal MCLG^{iv} ppb |
|--|--|---|--------------------------------|--|
| Alachlor | 4 | 2 | 2 | 0 |
| Antimony | 20 | 6 | 6 | 6 |
| Benzo[a]pyrene | 0.004 | 0.2 | 0.2 | 0 |
| Chlordane | 0.03 | 0.1 | 2 | 0 |
| Copper | 170 | 1,300 AL ^v | 1,300 AL | 1,300 AL |
| Cyanide | 150 | 200 | 200 | 200 |
| Dalapon | 790 | 200 | 200 | 200 |
| Diethylhexylphthalate (DEHP) | 12 | 4 | 6 | 0 |
| 1,2-Dichlorobenzene (1,2-DCB) | 600 | 600 | 600 | 600 |
| 1,4-Dichlorobenzene (1,4-DCB) | 6 | 5 | 75 | 75 |
| 2,4-Dichlorophenoxyacetic acid (2,4-D) | 70 | 70 | 70 | 70 |
| Dinoseb | 14 | 7 | 7 | 7 |
| Endothall | 580 | 100 | 100 | 100 |
| Ethylbenzene | 300 | 700 | 700 | 700 |
| Fluoride | 1,000 | 1,400-2,400 | 4,000 | 4,000 |
| Glyphosate | 1,000 | 700 | 700 | 700 |
| Lead | 2 | 15 AL | 15 AL | 0 |
| Nitrate | 10,000 as N | 10,000 as N | 10,000 as N | 10,000 as N |
| Nitrite | 1,000 as N | 1,000 as N | 1,000 as N | 1,000 as N |
| Nitrate and Nitrite | 10,000 as N | 10,000 as N | 10,000 as N | 10,000 as N |
| Oxamyl | 50 | 200 | 200 | 200 |
| Pentachlorophenol (PCP) | 0.4 | 1 | 1 | 0 |
| Picloram | 500 | 500 | 500 | 500 |
| Trichlorofluoromethane (Freon 11) | 700 | 150 | N/A | N/A |
| Trichlorotrifluoroethane (Freon 113) | 4,000 | 1,200 | N/A | N/A |
| Uranium | 1 (2 pCi/L) | 20 | 20 | 0 |
| Xylene(s) | 1,800 | 1,750 | 10,000 | 10,000 |

ⁱ Public Health Goals (PHGs) are developed by the Office of Environmental Health Hazard Assessment (OEHHA), California Environmental Protection Agency (Cal/EPA)

ⁱⁱ ppb = parts per billion, or micrograms per liter (µg/L)

ⁱⁱⁱ Maximum Contaminant Level

^{iv} Maximum Contaminant Level Goal

^v Action Level